

FOR YOUR SAFETY

If you smell gas:

1. Open windows.
2. DO NOT try to light any appliance.
3. DO NOT use electrical switches.
4. DO NOT use any telephone in your building.
5. Extinguish any open flame.
6. Leave the building.
7. Immediately call your local gas supplier after leaving the building. Follow the gas supplier's instructions.
8. If you cannot reach your gas supplier, call the Fire Department.

WARNING



Fire Hazard

Keep all flammable objects, liquids and vapors the minimum required clearances to combustibles away from heater.

Some objects will catch fire or explode when placed close to heater.

Failure to follow these instructions can result in death, injury or property damage.

GORDON RAY®
ROBERTS GORDON®

Model DF

Gas-Fired, Low Intensity Two Stage Unitary Heater

Installation, Operation & Service Manual

DF-80
DF-100
DF-125
DF-150
DF-175
DF-200

WARNING

Improper installation, adjustment, alteration, service or maintenance can result in death, injury or property damage. Read the Installation, Operation and Service Manual thoroughly before installing or servicing this equipment.

Installation must be done by a contractor qualified in the installation and service of gas-fired heating equipment or your gas supplier.

Installer

Please take the time to read and understand these instructions prior to any installation. Installer must give a copy of this manual to the owner.

Owner

Keep this manual in a safe place in order to provide your service technician with necessary information.



Roberts-Gordon LLC
1250 William Street
Buffalo, New York 14240-0044

www.robertsgordon.com

TABLE OF CONTENTS

SECTION 1: Heater Safety	1	10.4 Ladder Diagram	54
1.1 Manpower Requirements	1	10.5 Electrical Connection to the Burner	54
1.2 Safety Labels and Their Placement.....	1	SECTION 11: Operation and Maintenance	55
1.3 California Proposition 65	1	11.1 Sequence of Operation	55
SECTION 2: Installer Responsibility	4	11.2 High/Low Firing Operation.....	55
2.1 Wall Tag	4	11.3 Sequence of Operation	55
2.2 Corrosive Chemicals.....	4	11.4 To Shut Off Heater	56
2.3 National Standards and Applicable Codes.....	4	11.5 To Start Heater	56
SECTION 3: Clearances to Combustibles	5	11.6 Pre-Season Maintenance and Annual Inspection.....	56
3.1 Required Clearances to Combustibles.....	5	11.7 Maintenance Checklist	56
SECTION 4: National Standards and Applicable Codes	10	SECTION 12: Troubleshooting	58
4.1 Gas Codes	10	12.1 Troubleshooting Flow Chart	59
4.2 Aircraft Hangars	10	12.2 Manifold Gas Pressure Setting	61
4.3 Public Garages	10	SECTION 13: Replacement Parts	62
4.4 Electrical	10	SECTION 14: General Specifications	65
4.5 Venting.....	10	14.1 Material Specifications.....	65
4.6 High Altitude	10	14.2 Heater Specifications.....	65
SECTION 5: Major Components	11	14.3 Suspension Specifications.....	65
5.1 Standard Parts List	13	14.4 Controls Specifications	65
SECTION 6: Heater Installation	15	SECTION 15: The ROBERTS GORDON® GORDONRAY® DF	
SECTION 7: Optional Heater Accessories	30	Warranty	68
7.1 U-Tube Configuration.....	30		
7.2 Elbow Package Configuration.....	33		
7.3 Reflector Side Extension	36		
7.4 Lower Clearance Shield Installation	37		
7.5 Two-Foot Decorative Grille Installation	37		
7.6 Protective Grille Installation	39		
SECTION 8: Venting	40		
8.1 Venting.....	40		
8.2 Unvented Operation.....	41		
8.3 Horizontal Venting (Category III).....	41		
8.4 Vertical Venting (Category III)	41		
8.5 Unvented Operation Tube Termination.....	42		
8.6 Length Requirements	42		
8.7 Vent Material Recommendations	42		
8.8 Horizontal Venting (Category III) 4" (10 cm) Pipe	43		
8.9 Vertical Venting (Category III) 4" (10 cm) Pipe.....	43		
8.10 Common Side Wall Horizontal Venting (Category III).....	44		
8.11 Common Vertical Venting (Category III)	45		
8.12 Outside Combustion Air Supply	46		
SECTION 9: Gas Piping	49		
SECTION 10: Wiring	51		
10.1 Dual Stage Low Voltage Thermostat Wiring.....	51		
10.2 Multiple Burners For Connection To One Thermostat.....	52		
10.3 Internal Wiring.....	53		

© 2023 Roberts-Gordon LLC

All rights reserved. No part of this work covered by the copyrights herein may be reproduced or copied in any form or by any means - graphic, electronic, or mechanical, including photocopying, recording, taping or information storage and retrieval systems - without the written permission of Roberts-Gordon LLC.

SECTION 1: HEATER SAFETY



Your Safety is Important to Us!
This symbol is used throughout the manual to notify you of possible fire, electrical or burn hazards. Please pay special attention when reading and following the warnings in these

sections.

Installation, service and annual inspection of heater must be done by a contractor qualified in the installation and service of gas-fired heating equipment.

Read this manual carefully before installation, operation or service of this equipment.

This heater is designed for heating nonresidential indoor spaces. Do not install in residential spaces. This heater is not certified to meet the requirements of NFPA30A-2012 Section 7.6.6. (maximum tube temperature of 750 °F (399 °C)). Do not install this heater in facilities where compressed natural gas (CNG) or liquid natural gas (LNG) are present. These instructions, the layout drawing, local codes and ordinances, and applicable standards that apply to gas piping, electrical wiring, venting, etc. must be thoroughly understood before proceeding with the installation.

Protective gear is to be worn during installation, operation and service in accordance to the Occupational Safety and Hazard Administration (OSHA). Gear must be in accordance to NFPA 70E, latest revision when working with electrical components. Thin sheet metal parts have sharp edges. To prevent injury, the use of work gloves is recommended. The use of gloves will also prevent the transfer of body oils from the hands to the surface of the reflector.

Before installation, check that local distribution conditions, nature of gas and pressure, and adjustment of the appliance are compatible.

This heater must be applied and operated under the general concepts of reasonable use and installed using best building practices.

This appliance is not intended for use by persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction concerning use of the appliance by a person responsible for their safety. Children should be supervised to ensure that they do not play with the appliance.

For additional copies of the Installation, Operation and Service Manual, please contact Roberts-Gordon LLC.

1.1 Manpower Requirements

To prevent personal injury and damage to the heater, two persons will be required for installation.

1.2 Safety Labels and Their Placement

Product safety signs or labels should be replaced by the product user when they are no longer legible. Please contact Roberts-Gordon LLC or your ROBERTS GORDON® independent distributor to obtain replacement signs or labels. See *Page 2, Figure 1 through Page 3, Figure 2*.

1.3 California Proposition 65

In accordance with California Proposition 65 requirements, a warning label must be placed in a highly visible location on the outside of the equipment (i.e., near equipment's serial plate). See label placement drawing on *Page 3, Figure 2* for label location. Avoid placing label on areas with extreme heat, cold, corrosive chemicals or other elements. To order additional labels, please contact Roberts-Gordon LLC or your ROBERTS GORDON® independent distributor.

FIGURE 1: Top and Bottom Panel Label Placement







FIGURE 2: Side and Back Panel Label Placement




Side Panel




Back Panel




Rating Plate Label




Proposition 65 Label




Control Door (Inside)



Lighting Instruction Plate Label




Wiring Label



Control Side Panel

Description	Part Number
Rating Plate Label	91010401
Lighting Instruction Plate Label	91029602
Wiring Label	91032801
Clearances to Combustibles Label	91010461
Proposition 65 Label	91070016
Thermostat Connection Label	91033000

Clearances to Combustibles Label



SECTION 2: INSTALLER RESPONSIBILITY

The installer is responsible for the following:

- To install the heater, as well as the gas and electrical supplies, in accordance with applicable specifications and codes. Roberts-Gordon LLC recommends the installer contact a local Building Inspector or Fire Marshal for guidance.
- To use the information given in a layout drawing and in the manual together with the cited codes and regulations to perform the installation.
- To install the heater in accordance with the clearances to combustibles.
- To furnish all needed materials not furnished as standard equipment.
- To plan location of supports.
- To provide access on all sides for burner servicing and removal.
- To provide the owner with a copy of this Installation, Operation and Service Manual.
- To never use heater as a support for a ladder or other access equipment and never hang or suspend anything from heater.
- To ensure there is adequate air circulation around the heater and to supply air for combustion, ventilation and distribution in accordance with local codes.
- To safely and adequately install heater using materials with a minimal working load of 75 lbs (33 kg).
- To ensure the heater is placed in an approved application.

2.1 Wall Tag

A laminated wall tag is available for the heater as a permanent reminder of the safety instructions and the importance of the required clearances to combustibles. Please contact Roberts-Gordon LLC or your ROBERTS GORDON® independent distributor to obtain the wall tag. Affix the tag by peeling off the backing of the adhesive strips on the rear surface and position the tag on a wall near the heater (e.g. thermostat or ROBERTS GORDON® Controller).

A copy of the wall tag (P/N 91037912) is illustrated on the back cover. For an immediate solution, you may affix this copy on the wall near the heater.

Know your model number and installed configuration. Model number and installed configuration are found on the burner and in the Installation, Operation and Service Manual. and Page 6, Figure 3 through Page 8, Figure 11. Write the proper clearance dimensions in

permanent ink according to your model number and configuration in the open spaces on the tag.

2.2 Corrosive Chemicals

! CAUTION

<p style="text-align: center;">Product Damage Hazard</p> <p>Do not use heater in area containing corrosive chemicals.</p> <p>Refer to appropriate Material Safety Data Sheets (MSDS).</p> <p>Failure to follow these instructions can result in product damage.</p>

Roberts-Gordon LLC cannot be responsible for ensuring that all appropriate safety measures are undertaken prior to installation; this is entirely the responsibility of the installer. It is essential that the contractor, the sub-contractor, or the owner identifies the presence of combustible materials, corrosive chemicals or halogenated hydrocarbons* anywhere in the premises.

** **Halogenated Hydrocarbons** are a family of chemical compounds characterized by the presence of halogen elements (fluorine, chlorine, bromine, etc.). These compounds are frequently used in refrigerants, cleaning agents, solvents, etc. If these compounds enter the air supply of the burner, the life span of the heater components will be greatly reduced. An outside air supply must be provided to the burners whenever the presence of these compounds is suspected. Warranty will be invalid if the heater is exposed to halogenated hydrocarbons.*

2.3 National Standards and Applicable Codes

All appliances must be installed in accordance with the latest revision of the applicable standards and national codes. This refers also to the electric, gas and venting installation. Note: Additional standards for installations in public garages, aircraft hangars, etc. may be applicable.

SECTION 3: CLEARANCES TO COMBUSTIBLES

3.1 Required Clearances to Combustibles

Clearances are the required distances that combustible objects must be away from the heater to prevent serious fire hazards. Combustibles are materials that may catch on fire and include common items such as wood, paper, rubber, fabric, etc.

Maintain clearances to combustibles at all times for safety.

Clearances for all heater models are located on the burner of the heater and on *Page 6, Figure 3 through Page 8, Figure 11* in this manual. Check the clearances on each burner for the model heater being installed to make sure the product is suitable for your application and the clearances are maintained. Read and follow the safety guidelines below:

- Keep gasoline or other combustible materials including flammable objects, liquids, dust or vapors away from this heater or any other appliance.
- The stated clearances to combustibles represents a surface temperature of 90 °F (32 °C) above room temperature. Building materials with a low heat tolerance (such as plastics, vinyl siding, canvas, tri-ply, etc) may be subject to degradation at lower temperatures. It is the installer's responsibility to assure that adjacent materials are protected from degradation.
- Maintain clearances from heat sensitive equipment and workstations.
- Maintain clearances from vehicles parked below the heater.
- Maintain clearances from swinging and overhead doors, overhead cranes, vehicle lifts, partitions, storage racks, hoists, building construction, etc.
- In locations used for the storage of combustible materials, signs must be posted to specify the maximum permissible stacking height to maintain required clearances from the heater to the combustibles. Signs must be posted adjacent to the heater thermostat. In the absence of a thermostat, signs must be posted in a conspicuous location.
- Consult local Fire Marshal, Fire Insurance Carrier or other authorities for approval of proposed installation when there is a possibility of exposure to combustible airborne materials or vapors.
- Hang heater in accordance to the minimum suspension requirements on *Page 17, Figure 15*.

! WARNING



Fire Hazard

Keep all flammable objects, liquids and vapors the minimum required clearances to combustibles away from heater.

Some objects will catch fire or explode when placed close to heater.

Failure to follow these instructions can result in death, injury or property damage.

- If the radiant tubes must pass through the building structure, be sure that adequate sleeving and fire stop is installed to prevent scorching and/or fire hazard.

- NOTE:** 1. All dimensions are from the surfaces of all tubes, couplings and elbows.
 2. Clearances B, C and D can be reduced by 50% after 25' (7.5 m) of tubing downstream from where the burner and burner tube connect.

FIGURE 3: Level Reflector


	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	6	38	65	38	16	97	166	97
	DF-100	6	40	70	40	16	102	178	102
	DF-125	6	46	76	46	16	117	194	117
	DF-150	6	50	79	50	16	127	201	127
	DF-175	8	52	82	52	21	133	209	133
	DF-200	8	52	96	52	21	133	244	133

FIGURE 4: One Side Reflector



	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	6	9	69	54	16	23	176	138
	DF-100	6	9	76	59	16	23	194	150
	DF-125	6	9	82	65	16	23	209	166
	DF-150	6	9	85	69	16	23	216	176
	DF-175	8	9	88	73	21	23	224	186
	DF-200	8	18	102	73	21	46	260	186

FIGURE 5: Two Side Reflectors

	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	6	25	71	25	16	64	181	64
	DF-100	6	27	77	27	16	69	196	69
	DF-125	6	32	83	32	16	82	211	82
	DF-150	6	35	87	35	16	89	221	89
	DF-175	8	40	91	40	21	102	232	102
	DF-200	8	40	102	40	21	102	260	102

- NOTE:** 1. All dimensions are from the surfaces of all tubes, couplings and elbows.
 2. Clearances B, C and D can be reduced by 50% after 25' (7.5 m) of tubing downstream from where the burner and burner tube connect.

FIGURE 6: 45° Tilt Reflector


	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	8	8	65	60	21	21	166	153
	DF-100	10	8	73	64	26	21	186	163
	DF-125	10	8	77	69	26	21	196	176
	DF-150	12	8	83	74	31	21	211	188
	DF-175	12	8	85	79	31	21	216	201
	DF-200	12	10	85	79	31	26	216	201

FIGURE 7: U-Tube, Standard Reflector



	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	6	38	68	37	16	97	173	94
	DF-100	6	40	75	39	16	102	191	100
	DF-125	6	46	78	43	16	117	199	110
	DF-150	6	50	83	47	16	127	211	120
	DF-175	8	54	87	51	21	138	221	130
	DF-200	8	54	102	51	21	138	260	130

FIGURE 8: U-Tube, 45°

	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	8	8	65	46	21	21	166	117
	DF-100	8	8	73	52	21	21	186	133
	DF-125	8	8	77	61	21	21	196	155
	DF-150	8	8	83	66	21	21	211	168
	DF-175	8	8	85	70	21	21	216	178
	DF-200	8	8	85	70	21	21	216	178

- NOTE:** 1. All dimensions are from the surfaces of all tubes, couplings and elbows.
 2. Clearances B, C and D can be reduced by 50% after 25' (7.5 m) of tubing downstream from where the burner and burner tube connect.

FIGURE 9: U-Tube, Opposite 45° Reflector


	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	8	60	65	22	21	153	166	56
	DF-100	10	64	73	22	26	163	186	56
	DF-115/125	10	70	77	22	26	178	196	56
	DF-140/150	12	74	83	22	31	188	211	56
	DF-175	12	76	85	22	31	194	216	56
	DF-200	12	76	85	22	31	194	216	56

FIGURE 10: 2-Foot Deco Grille and Protective Grille



	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	6	38	65	38	16	97	166	97
	DF-100	6	40	70	40	16	102	178	102
	DF-125	6	46	76	46	16	117	194	117
	DF-150	6	50	79	50	16	127	201	127
	DF-175	8	52	82	52	21	133	209	133
	DF-200	8	52	96	52	21	133	244	133


FIGURE 11: Lower Clearance Shield*

	Model	(inches)				(centimeters)			
		A	B	C	D	A	B	C	D
	DF-80	6	40	38	40	16	102	97	102
	DF-100	6	50	44	50	16	127	112	127
	DF-125	6	54	48	54	16	138	122	138
	DF-150	6	55	50	55	16	140	127	140
	DF-175	- UNAPPROVED -				- UNAPPROVED -			
	DF-200	- UNAPPROVED -				- UNAPPROVED -			

*When installed in the first 10' (3 m).

- NOTE:** 1. All dimensions are from the surfaces of all tubes, couplings and elbows.
 2. Clearances B, C and D can be reduced by 50% after 25' (7.5 m) of tubing downstream from where the burner and burner tube connect.

FIGURE 12: Venting

	Model	(inches)			(centimeters)		
		A	E	F	A	E	F
	DF-80	20	24	18	51	61	46
	DF-100	20	24	18	51	61	46
	DF-125	20	24	18	51	61	46
	DF-150	20	30	18	51	77	46
	DF-175/200	20	30	18	51	77	46

SECTION 4: NATIONAL STANDARDS AND APPLICABLE CODES

4.1 Gas Codes

Type of gas appearing on the nameplate must be the type of gas used. Installation must comply with national and local codes and requirements of the local gas company.

United States: Refer to National Fuel Gas Code NFPA 54/ANSI Z223.1 - latest revision.

Canada: Refer to Natural Gas and Propane Installation Code CSA B149.1 - latest revision.

4.2 Aircraft Hangars

Installation in aircraft hangars must be in accordance with the following codes:

United States: Refer to Standard for Aircraft Hangars, NFPA 409 - latest revision.

Canada: Refer to Natural Gas and Propane Installation Code CSA B149.1 - latest revision.

In aircraft storage and servicing areas, heaters shall be installed at least 10' (3 m) above the upper surface of wings or of engine enclosures of the highest aircraft which may be housed in the hangar. The measurement shall be made from the wing or engine enclosure (whichever is higher from the floor) to the bottom of the heater.

- In shops, offices and other sections of aircraft hangars communicating with aircraft storage or servicing areas, heaters shall be installed not less than 8' (2.4 m) above the floor.
- Suspended or elevated heaters shall be so located in all spaces of aircraft hangars that they shall not be subject to injury by aircraft, cranes, movable scaffolding or other objects. Provisions shall be made to assure accessibility to suspended heaters for recurrent maintenance purposes.

4.3 Public Garages

Installation in garages must be in accordance with the following codes:

United States: Refer to Standard for Parking Structures NFPA 88A - latest revision or the Code for Motor Fuel Dispensing Facilities and Repair Garages, NFPA 30A - latest revision.
Canada: Refer to Natural Gas and Propane Installation Code CSA B149.1 - latest revision.

- Heaters must not be installed less than 8' (2.4 m) above the floor. Minimum clearances to combustibles must be maintained from vehicles parked below the heater.
- When installed over hoists, minimum clearances to combustibles must be maintained from the upper most point of objects on the hoist.

4.4 Electrical

Heater must be electrically grounded in accordance with the following codes:

United States: Refer to National Electrical Code®, NFPA 70 - latest revision. Wiring must conform to the most current National Electrical Code®, local ordinances and any special diagrams furnished.

Canada: Refer to Canadian Electrical Code, CSA C22.1 Part 1 - latest revision.

4.5 Venting

Venting must be installed in accordance with the requirements within this manual and the following codes:

United States: Refer to National Fuel Gas Code NFPA 54/ANSI Z223.1 - latest revision.

Canada: Refer to Natural Gas and Propane Installation Code CSA B149.1 - latest revision.

4.6 High Altitude


These heaters are approved for installations up to 2000' (610 m) (US), 4500' (1370 m) (Canada) without modification. Consult factory if US installation is above 2000' (610 m) or Canadian installation is above 4500' (1370 m).

SECTION 5: MAJOR COMPONENTS


FIGURE 13: Major Component Descriptions - Standard Reflector

Burner with Tube Gasket


Must be installed with the flame observation window facing down.

**Standard Reflector (Aluminum or Stainless Steel)**


Alternate overlap as shown on overview and on Page 19, Figure 17. Minimum overlap is 6" (16 cm).

**Burner Tube**



Supplied in 10' (3 m) lengths. Burner tube is always the first tube after the burner.

**Tube**


Hot rolled or heat treated aluminized tube supplied in 10' (3 m) lengths.

**Tube and Reflector Hanger with Clamp Package**




Position this hanger no more than 4" (10 cm) away from the burner.

**Coupling Assembly with Lock****Reflector End Cap**

Punch out center section to accommodate tube.

**Tube and Reflector Hanger**

Suspend system from these hangers.

**Vent Adapter****Reflector Support Strap & Wire Form****Turbulator/Swirlor**

Install turbulator/swirlor as specified in the "Turbulator and Swirlor Installation" charts. See Pages 23 and 24.




**Flex Gas Line with Shut Off Cock**



FIGURE 14: Major Component Descriptions - High Efficiency Reflector




Burner with Tube Gasket
Must be installed with the flame observation window facing down.

High Efficiency Reflector (Aluminum only)


Alternate overlap as shown on overview and on Page 19, Figure 17. Minimum overlap is 6" (16 cm).




Burner Tube
Supplied in 10' (3 m) lengths. Burner tube is always the first tube after the burner.




Tube
Hot rolled or heat treated aluminized tube supplied in 10' (3 m) lengths.




Tube and Reflector Hanger with Clamp Package-EF
Position this hanger no more than 4" (10 cm) away from the burner.




Coupling Assembly with Lock




Tube and Reflector Hanger-EF
Suspend system from these hangers.




Reflector End Cap-EF
Punch out center section to accommodate tube.




Vent Adapter



Reflector Support Strap & Wire Form-EF



Flex Gas Line with Shut Off Cock



Turbulator/Swirlor
Install turbulator/swirlor as specified in the "Turbulator and Swirlor Installation" charts. See Pages 23 and 24.

5.1 Standard Parts List

Table 1: Contents of DF-Series Burner Carton

Part No.	Description	DF-80	DF-100	DF-125	DF-150	DF-175	DF-200
073XXXXX	Burner (Rate and Fuel Varies)	1	1	1	1	1	1
90709700	Blower Assembly with Cord	1	1	1	1	1	1
02568200	Gasket (Burner to Burner Tube)	1	1	1	1	1	1
90709801	Gasket (Blower to Burner)	1	1	1	1	1	1
173101NA	Installation, Operation and Service Manual	1	1	1	1	1	1
91201708	Pipe Nipple (Black) 1/2" NPT x 4"	1	1	1	1	1	1
94273914	Hex Head Bolts 5/16" - 18 Rolok	4	4	4	4	4	4
96411600	Split Lock Washer	4	4	4	4	4	4
*91412200	Flexible Stainless Steel Gas Hose, 1/2" NPT (US Models Only)	1	1	1	-	-	-
91412203	Flexible Stainless Steel Gas Hose, 3/4" NPT (US Models Only)	-	-	-	1	1	1
91907302	S-Hooks	2	2	2	2	2	2
91911704	Outside Air Collar	1	1	1	1	1	1
94118106	#8 x 3/8 Hex Washer Head (for Outside Air Collar)	3	3	3	3	3	3
92311800	Keps Nut	4	4	4	4	4	4
03051501	Turbulator Adapter	1	1	1	1	-	-
03051502	Turbulator 2.5' (76 cm), Aluminized Steel	4	2	3	2	-	-
**03051509K	Swirler Package - 10' (3 m) (Contains Qty 2 - 62" Swirlers)	-	-	-	-	-	1
**03051510K	Swirler Package - 15' (4.5 m) (Contains Qty 3 - 62" Swirlers)	-	-	-	-	1	-

*Canadian models: Rubber (Type 1) Gas Hoses available as an accessory. See Page 51.

**Contents located in box separate from the burner.

Table 2: Contents of Standard Core and Extension Packages

Part No.	Description	Core Packages				Extension Packages			
		Aluminized				Aluminized			
		10' (3m)	20' (6m)	30' (9m)	40' (12m)	10' (3m)	20' (6m)	30' (9m)	40' (12m)
91409408	Tube, HT Aluminized, 10' (3 m)	-	1	2	3	1	2	3	4
03051101	Burner Tube, ALUMI-THERM® Steel, 10' (3 m)	-	-	1	1	-	-	-	-
03051601	Burner Tube, HT ALUMI-THERM® Steel, 10' (3 m)	1	1	-	-	-	-	-	-
01312700	Coupling Assembly	-	1	2	3	1	2	3	4
02750303	Standard Reflector, 8' (3.5 m)	2	3	4	6	2	3	4	6
02750800	End Cap	2	2	2	2	-	-	-	-
03090100	Tube and Reflector Hanger	2	3	4	5	1	2	3	4
91907302	S-Hook	2	3	4	5	1	2	3	4
03050010	Reflector Support Package (Strap, Wire Form, Screws)	1	2	3	5	2	3	4	6
91107720	U-Clip Package	1	1	1	1	1	1	1	1
90502701	Vent Adapter	1	1	1	1	-	-	-	-
01318901	Tube Clamp Package	1	1	1	1	-	-	-	-

Table 2: Contents of Standard Core and Extension Packages

Part Number	CP10ALUM	CP20ALUM	CP30ALUM	CP40ALUM	EXP10ALUM	EXP20ALUM	EXP30ALUM	EXP40ALUM
-------------	----------	----------	----------	----------	-----------	-----------	-----------	-----------

Table 3: Contents of High Efficiency Core and Extension Packages

Part No.	Description	Core Packages				Extension Packages			
		Aluminized				Aluminized			
		10' (3m)	20' (6m)	30' (9m)	40' (12m)	10' (3m)	20' (6m)	30' (9m)	40' (12m)
91409408	Tube, HT Aluminized, 10' (3 m)	-	1	2	3	1	2	3	4
03051101	Burner Tube, ALUMI-THERM® Steel, 10' (3 m)	-	-	1	1	-	-	-	-
03051601	Burner Tube, HT ALUMI-THERM® Steel, 10' (3 m)	1	1	-	-	-	-	-	-
01312700	Coupling Assembly	-	1	2	3	1	2	3	4
02750313	High Efficiency Reflector, 8' (3.5 m)	2	3	4	6	2	3	4	6
02750802	End Cap-EF	2	2	2	2	-	-	-	-
03090102	Tube and Reflector Hanger-EF	2	3	4	5	1	2	3	4
91907302	S-Hook	2	3	4	5	1	2	3	4
03050012	Reflector Support Package-EF (Strap, Wire Form, Screws)	1	2	3	5	2	3	4	6
91107720	U-Clip Package	1	1	1	1	1	1	1	1
90502701	Vent Adapter	1	1	1	1	-	-	-	-
01318902	Tube Clamp Package-EF	1	1	1	1	-	-	-	-
Part Number		CP10ALUMEF	CP20ALUMEF	CP30ALUMEF	CP40ALUMEF	EXP10ALUMEF	EXP20ALUMEF	EXP30ALUMEF	EXP40ALUMEF

Table 4: DF-Series Component Package Guide

Model	Tubing Length	Standard Reflector Core Packages	High Efficiency Reflector Core Packages
	Minimum	Aluminized	Aluminized
DF-80	20' (6 m)	CP20ALUM	CP20ALUMEF
DF-100	30' (9 m)	CP30ALUM	CP30ALUMEF
DF-125	30' (9 m)	CP30ALUM	CP30ALUMEF
DF-150	40' (12 m)	CP40ALUM	CP40ALUMEF
DF-175	40' (12 m)	CP40ALUM	CP40ALUMEF
DF-200	50' (15 m)	CP30ALUM + EXP20ALUM	CP30ALUMEF + EXP20ALUMEF

Additional tubing length may be added to heater. Tubing must be heat-treated, aluminized or porcelain coated. Any additional tubing lengths are considered as vent length for length determination. Maximum venting length for minimum heater length is 45' (13.7 m) total.

Table 5: DF-Series Component Package Guide - High Efficiency Reflector

Model	Tubing Length	Core Packages	
	Minimum	Hot Rolled	Aluminized
DF-80	20' (6 m)	CP20HRSEF	CP20ALUMEF
DF-100	30' (9 m)	CP30HRSEF	CP30ALUMEF
DF-125	30' (9m)	CP30HRSEF	CP30ALUMEF
DF-150	40' (12 m)	CP40HRSEF	CP30ALUMEF
DF-175	40' (12 m)	CP40HRSEF	CP40ALUMEF
DF-200	50' (15 m)	CP30HRSEF + EXP20HRSEF	CP30ALUMEF + EXP20ALUMEF

Although not recommended, additional tube lengths may be added to the heater. Tubing must be hot-rolled steel, aluminized (heat-treated) or porcelain coated. Additional tube lengths beyond the specified minimum tubing length are considered vent pipe for length determination.

SECTION 6: HEATER INSTALLATION**⚠ WARNING****Severe Injury Hazard**

Secure burner to burner tube with nuts and lockwashers.

Hang heater with materials with a minimum working load of 75 lbs (33 kg).

Failure to follow these instructions can result in death, injury or property damage.

Expansion and contraction of the tube dictates that the minimum suspension lengths must be maintained. See *table on Page 17, Figure 15*.

⚠ WARNING**Cut/Pinch Hazard**

Wear protective gear during installation, operation and service.

Edges are sharp.

Failure to follow these instructions can result in injury.

To ensure your safety and comply with the terms of the warranty, all units must be installed in accordance with these instructions.

The gas or the electrical supply lines must not be used to support the heater.


Do not locate the gas or electric supply lines directly over the path of the flue products from the heater.

The heater must be installed in a location that it is readily accessible for servicing.

The heaters must be installed in accordance with clearances to combustibles as indicated on the rating plate and in this instruction manual.

The minimum and maximum gas inlet pressures must be maintained as indicated on the rating plate.

Typical installation configurations are shown on *Page 17, Figure 15*.

FIGURE 15: Critical Hanger Placement

NOTE: Suspension material provided by others.

Description	Part Number
S-Hook	91907302
Tube/Reflector Hanger	0309010X

Run Length	Typical Expansion	Minimum "X" Length
10' (3 m) - 50' (15.2 m)	±1" (3 cm)	12" (30.5 cm)
51' (15.5 m) - 60' (18.3 m)	±2" (5 cm)	18" (45.7 cm)
61' (18.6 m) - 80' (24.4 m)	±3" (8 cm)	24" (61 cm)

FIGURE 16: Linear Heater Assembly Overview










FIGURE 17: Linear Heater Layout Overview

FIGURE 18: Linear Heater Layout Overview (Continued)




Step 6.1 Burner Tube Installation

NOTE:
Tubing requires a downward slope of 1/2" (13 mm) per 20' (6 m) away from burner.

The diagram illustrates the installation of a burner tube. It shows a burner tube being suspended by S-hooks and hangers. The distance between the hangers is specified as 7' 6" ± 1' (229 cm ± 25 cm). A circular inset provides a close-up view of the burner tube connection, showing the offset mounting hole and the weld seam. Labels indicate that the offset mounting hole must be to the top and the weld seam must be to the bottom of the tube.

Description	Part Number
Burner Tube	03051XXX
S-Hook	91907302
Tube/Reflector Hanger	0309010X


Step 6.2 Tube Clamp Package Installation




Step 6.3 Coupling and Tube Assembly

NOTE: Prior to coupling installation review Swirler Installation on Model DF-175 requires swirler tab to be installed under coupling. Swirler installation for this model must be complete prior to coupling installation.


A Close coupling and slide opposite end into tab. Position tab underneath guide rail.




B Insert wide end of slide bar/coupling lock into guide rail on opposite end of tabs. Slide the slide bar/coupling lock up the guide rail until snug (approximately 3" (8 cm) to 4" (10 cm)).



C Insert tubes into coupling until end of each tube rests against internal pins.




D




Description	Part Number
Coupling	01329600
Slide Bar/Coupling Lock	01329700
Tube	91409XXX

Step 6.3.1 Coupling and Tube Assembly (Continued)

Tighten slide bar as shown below.



- Repeat Step 6.3 A - D until all tubes are assembled. See Page 23, Step 6.3.2.

Step 6.3.2 Coupling and Tube Assembly (Continued)

Model	Tube Length Minimum
DF-80	20' (6 m)
DF-100	30' (9 m)
DF-125	30' (9 m)
DF-150	40' (12 m)
DF-175	40' (12 m)
DF-200	50' (15 m)

Step 6.4 Turbulator Installation

Install turbulator as specified in the “Turbulator Installation” chart below.

Model	Tube Section
DF-80	2nd 10' (3 m) Section
DF-100	3rd 10' (3 m) Section

Turbulator Section

Turbulator Adapter

Tab

Twist

Pull String


Fold tab around outside of tube nearest to the vent to hold turbulator in place.

Description	Part Number
Turbulator Adapter 2.5' (76.2 cm)	03051501
Turbulator Section 2' (61 cm)	03051502
Tube	91409XXX

Step 6.5 Swirler Installation

Swirler Installation Chart		
Model	Tube Section	Swirler Qty
DF-125	3rd 10' (3m) Section	1 Starter + 3 Adapters
DF-150	4th 10' (3m) Section	1 Starter + 1 Adapter
DF-175	4th 10' (3 m) Section	1 Starters + 2 Adapters
DF-200	5th 10' (3 m) Section	1 Starter + 1 Adapter

Description	Part Number
Swirler Starter 62" (1.6 m)	03051506
Swirler Adapter 62" (1.6 m)	03051507
Tube	91409XXX



Swirler installation required for models specified in chart.

Begin installing swirler at end of tube section as described in the "Swirler Installation Chart" and continue towards burner.

Note: If heater length is extended 10' (3 m) beyond the specified minimum heat exchanger length swirler can begin in either the specified tube section (according to the "Swirler Installation Chart") or the end of the 10' (3 m) extension and continue towards burner.

Swirlers should not be installed through 180° "U" sections or elbows. For this reason, 15' long swirler package contains 2 swirler starter sections to allow for starter pieces to be installed before and after "U" sections and elbows. Swirler starter section identified as section with tab on end. Swirlers should be installed as shown in *Figure 19 through Figure 21*.

FIGURE 19: Swirler Installation Model: DF-175, 40' Straight Tube; Swirler Package - 15' (4.5 m) (p/n 03051510K)






FIGURE 20: Swirler Installation Model: DF-175, 40' Even U-Tube; Swirler Package - 15' (4.5 m) (p/n 03051510K)



See page 30 for U-Tube installation instructions.

FIGURE 21: Swirler Installation Model: DF-175, 40' Uneven U-Tube; Swirler Package - 15' (4.5 m) (p/n 03051510K)

See page 30 for U-Tube installation instructions.

FIGURE 22: Swirler Installation Model: DF-200, 50' Straight Tube; Swirler Package - 10' (3 m) (p/n 03051509K)





FIGURE 23: Swirler Installation Model: DF-200, 50' U-Tube; Swirler Package - 10' (3 m) (p/n 03051509K)



See page 30 for U-Tube installation instructions.


Step 6.6 Reflector Installation**⚠ WARNING****Fire Hazard**

Support reflector with reflector hanger and support strap.

Reflector must not touch tube.

Failure to follow these instructions can result in death, injury or property damage.

NOTE: All tube surfaces must be covered by a reflector, except for a U-tube.



Description	Part Number
Tube/Reflector Hanger	0309010X
Burner Tube	03051XXX
Reflector 96" (244 cm)	027503XX


Step 6.6.1 Reflector, U-Clip and Reflector Support Installation

The pictorial drawings of the heater construction in *Section 6* are schematic only and provide a general guideline of where hangers, reflector supports and U-clips are to be installed.

To ensure proper expansion and contraction movement of the reflectors, a combination of U-clips and reflector supports are used. The positioning of


reflector supports and U-clips depend on the individual installation. Use either pop rivets or sheet metal screws instead of u-clips when installing end caps and joint pieces in areas where impact and high wind may be a factor. The following rules must be observed.

1. Slide first reflector after burner a minimum 2" (4 cm) through first hanger and ensure reflector end cap is securely fastened via U-clips, pop rivets, or sheet metal screws. Position reflector support with tight screws in middle of first reflector.



2. The overlap at the first and second reflector is a **slip overlap**. Thereafter, every third reflector joint is a slip overlap. A slip overlap is achieved by either:
 - a.) both reflectors lay inside a hanger.


- (No reflector support needed.)
- b.) using a reflector support with loose screws at the reflector overlap.



3. The remaining reflector overlaps require a **non-slip overlap** connection. To affix the reflectors together in a non-slip overlap either:
 - a.) use reflector support and tight screws.

- b.) if both reflectors lay inside a hanger, u-clips or sheet metal screws may be used.

This section of three reflectors joined together must be affixed to the tube with at least one reflector support with tight screws.




Description	Part Number
Reflector Support Package	0305001X
Wire Form	9190800X
Reflector Support Strap	0305000X
Screw #8 x 3/4"	94320812
U-Clip Package	91107720
Reflector End Cap	027508XX

NOTE: High efficiency reflectors should NOT be used in applications exposed to wind.

Step 6.7 Burner Installation

Install combustion blower by placing blower gasket between blower and top of burner. Secure blower to top of burner using (4) supplied #10-32 locknuts. Install flue collar if connecting an outside air inlet. Plug blower cord into receptacle on rear of burner.

Note: Do NOT face blower air inlet towards hinged access panel if connecting fresh air inlet. Doing so will interfere with access panel.



Description	Part Number
Bolt	94273914
Lock Washer	96411600
Blower	90709700
Blower to Burner Gasket	90709801
Locknuts # 10-32	92311800
Outside Air Flue Collar	91911700
#8 x 3/8 Hex Washer Head	94118106
Burner to Burner Tube Gasket	02568200

NOTE: To ensure proper orientation, attach burner tube with tube weld facing downward.

SECTION 7: OPTIONAL HEATER ACCESSORIES**! WARNING****Cut/Pinch Hazard**

Wear protective gear during installation, operation and service.

Edges are sharp.

Failure to follow these instructions can result in injury.

7.1 U-Tube Configuration

Heaters are approved for optional U-tube configurations.

The U-tube may be installed in either a standard horizontal position, a 45° position or in an opposite 45° position as shown on *Page 7, Figure 7 through Page 8, Figure 9*. When using a U-tube configuration, the following additional rules must be adhered to:

- A minimum of 10' (3 m) on DF-80 and a minimum of 15' (4.5 m) on DF-100/125/150/175/200 is required between the burner and the U-tube.
- The correct turbulator/swirler (*See Page 24, Step 6.4*) must be installed in the last standard section of the tube.
- The burner must never be operated in a tilted position.
- The heater must be properly supported at all locations. *See Page 34, Figure 25.*


FIGURE 24: U-Tube Heater Assembly Overview








FIGURE 25: U-Tube Heater Layout Overview

FIGURE 26: U-Tube Layout Overview (Continued)

7.2 Elbow Package Configuration


Step 7.2.1 Elbow Installation




Description	Part Number
Elbow Package	0271870X
90° Elbow	01335801
Coupling	01312700
Reflector End Cap	0275080X
Reflector Joint Piece	0275090X
U-Clip Package	91107720

Minimum Distance Required Between Burner and Elbow	
Model	Minimum Distance
DF-80	10' (3 m)
DF-100	15' (4.5 m)
DF-125	15' (4.5 m)
DF-150	15' (4.5 m)
DF-175	15' (4.5 m)
DF-200	15' (4.5 m)


Step 7.2.2 Elbow Installation





Step 7.2.3 Reflector Joint Installation




Step 7.2.4 Reflector Joint Installation



Step 7.2.5 Reflector Joint Detail**FIGURE 27: Reflector Joint Detail**

7.3 Reflector Side Extension


Step 7.3.1 Bracket Installation



The diagram illustrates the installation of a reflector side extension bracket. A cylindrical tube is shown with a trapezoidal reflector attached to its side. A 'Tube and Reflector Hanger' is used to suspend the assembly. A 'Reflector Support' is shown as a vertical bracket. A 'Reflector Side Extension Bracket' is shown being attached to the side of the reflector. A note states: 'Use additional supports in high air movement applications.'

Description	Part Number
Reflector Side Extension Package	0271270X
Reflector Side Extension 96" (244 cm)	0136800X
Retainer Clips	02751200
Sheet Metal Screws	94118106
Order Separately	
Reflector Side Extension Bracket	01329911


Step 7.3.2 Side Reflector Installation



The diagram shows the side reflector being installed onto the side extension. A '#8 x 3/8 (3.9 x 9.5 mm) Sheet Metal Screw' is used to secure the reflector. A note indicates to 'Cut relief notches for supports and hangers.' 'Retainer Clips (2 per Side)' are used to hold the reflector in place. The 'Reflector Side Extension' is labeled.


7.4 Lower Clearance Shield Installation

Step 7.4.1 Shield Support Strap Assembly




7.5 Two-Foot Decorative Grille Installation

Step 7.5.1 Grille Installation




Step 7.5.2 Frame Shield Installation



Description	Part Number
Deco Grille Shield 24" (61 cm)	01365900

Step 7.5.3 Reflector Side Extension Installation for Decorative Grilles

NOTE: If the decorative grille system is to be installed in an area with considerable air movement, it is recommended that one #8 x 3/8" sheet metal screw be installed per reflector extension to prevent it from blowing over.




Distance "A"		Extension	
Minimum	Maximum	Part No.	Width
2" (4 cm)	6" (15 cm)	013704XX	8" (20 cm)
6" (15 cm)	10" (26 cm)	013704XX	12" (30 cm)
10" (26 cm)	14" (37 cm)	013704XX	16" (40 cm)

Description	Part Number
Reflector Side Extension 48" (122 cm)	013704XX

7.6 Protective Grille Installation

Step 7.6.1 Silicone Cap Installation




NOTE: Protective Grille NOT APPROVED for use with 45° tilted reflectors.


Description	Part Number
Grille Section	08050001
Grille End Cap	08050002
Grille Section - EF Reflector	08050003
Grille End Cap - EF Reflector	08050004
Silicone Cap	91915951-6P

Step 7.6.2 Grille End Cap Installation


A




B




C



D



Step 7.6.3 Grille Installation



SECTION 8: VENTING**⚠ WARNING****Carbon Monoxide Hazard**

Heaters installed unvented must be interlocked with sufficient building exhaust.

Heaters must be installed according to the installation manual.

Failure to follow these instructions can result in death or injury.

⚠ WARNING**Cut/Pinch Hazard**

Wear protective gear during installation, operation and service.

Edges are sharp.

Failure to follow these instructions can result in injury.

8.1 Venting

This heater is considered a Category III vented appliance. The Serial plate on the heater will indicate vent Category and this manual will describe the installation requirements for vent Category.

This heater must be vented in accordance with the rules contained in this manual and with the following national codes and any state, provincial or local codes which may apply:

United States: Refer to National Fuel Gas Code NFPA 54/ANSI Z223.1 - latest revision.

Canada: Refer to Natural Gas and Propane Installation Code CSA B149.1 - latest revision.

Exhaust end of heater will accept a 4" (10 cm) vent pipe using the vent adapter (P/N 90502701). To

prevent leakage of condensation, install the vent adapter with the seam on top and seal the joint using a high temperature silicone sealant.

Any portion of vent pipe passing through a combustible wall must have an approved thimble to conform with the above listed codes.

Vent pipe must be sloped downward away from the heater 1/2" (1 cm) for every 20' (6 m).

The heater may be individually vented or common vented. When venting horizontally, a maximum of two heaters can be commonly vented. *See Page 43, Section 8.3.* When venting vertically, a maximum of four heaters can be commonly vented. *See Page 47, Section 8.10.*

The heater may also be installed unvented in certain circumstances according to building ventilation codes. Refer to the above codes *and Page 43, Section 8.2* for further information. Unvented operation also requires compliance with the clearances to combustibles given *on Page 9, Figure 12.*

The bottom of the vent or air intake terminal shall not be located less than 1' (0.3 m) above grade level.

The vent shall not terminate less than 7' (2.1 m) above grade where located adjacent to public walkways.

Vent terminal must be installed at a height sufficient to prevent blockage by snow, and building materials protected from degradation by flue gases.

Secure all joints with #8 x 3/8 sheet metal screws. Seal all joints with high temperature silicone sealant.

Vent terminal must be beyond any combustible overhang.

8.1.1 United States Requirements

Vent must terminate at least 3' (0.9 m) above any forced air inlet located within 10' (3.1 m).

Vent must terminate at least 4' (1.2 m) below, 4' (1.2 m) horizontally from, or 1' (0.3 m) above any door, operable window, or gravity air inlet into any building.

8.1.2 Canadian Requirements

The vent shall not terminate within 6' (1.8 m) of a mechanical air supply inlet to any building.

The vent shall not terminate within 3' (0.9 m) of a window or door that can be opened in any building, any non-mechanical air supply inlet to any building, or of the combustion air inlet of any other appliance.

8.1.3 Vent Category Definitions

Radiant tube heaters are divided into four categories based on the static pressure produced in the vent and the percentage flue loss.

Category I – a radiant tube heater that operates with a non-positive vent static pressure and with a vent gas temperature that avoids excessive condensate production in the vent

Category II – a radiant tube heater that operates with a non-positive vent static pressure and with a vent gas temperature that can cause excessive condensate production in the vent

Category III - a radiant tube heater that operates with a positive vent static pressure and with a vent gas temperature that avoids excessive condensate production in the vent

Category IV - a radiant tube heater that operates with a positive vent static pressure and with a vent gas temperature that can cause excessive condensate production in the vent

This heater is considered a Category III vented appliance. The Serial plate on the heater will indicate vent Category and this manual will describe the installation requirements for vent Category.

8.2 Unvented Operation

Sufficient ventilation must be provided in the amount of 4 cfm per 1000 Btu/h firing rate (United States); 3 cfm per 1000 Btu/h firing rate (Canada).

Use of optional outside combustion air is not recommended with unvented heaters.

If exhaust fans are used to supply ventilation air, an interlock switch must be used to prevent the heater from coming on when the fans are off. This may be done using a pressure switch.

8.3 Horizontal Venting (Category III)

All horizontal venting configurations for this product are considered Category III.

In noncombustible walls only, vent terminal (P/N 02537801-1P) may be used.

For 4" (10 cm) vents in either combustible or noncombustible walls, use Tjernlund VH1-4 (P/N

90502100) or equivalent, insulated vent terminal. Follow the manufacturer's instructions for proper installation.

For 6" (15 cm) common vents in either combustible or noncombustible walls, use Tjernlund VH1-6 (P/N 90502101) or equivalent, insulated vent terminal.

Approved venting material for horizontal venting (Category III) must be single-wall corrosion resistant with a thickness of no less than 26 gauge. It is required that all vent pipes and connectors be fastened together with sheet metal screws and sealed with high temperature silicone sealant approved for at least 550 °F (288 °C) (supplied by others). The installer must perform a leak test on the complete venting system. A solution of soap and water should be used to test the venting system.

A continuous section of type B-vent may only be used to pass through the outside wall or outside of the building. Horizontal venting (Category III) does not allow the use of type B-vent inside of the space.

Follow the vent material manufacturer's instructions for proper installation.

8.4 Vertical Venting (Category III)

For 4" (10 cm) common or single heater vent, an approved vent cap (P/N 90502300) must be used.

For 6" (15 cm) common vent, an approved vent cap (P/N 90502302) must be used.

Approved venting material for vertical venting (Category III) must be single-wall corrosion resistant with a thickness of no less than 26 gauge. It is required that all vent pipes and connectors be fastened together with sheet metal screws and sealed with high temperature silicone sealant approved for at least 550 °F (288 °C) (supplied by others). The installer must perform a leak test on the complete venting system. A solution of soap and water should be used to test the venting system.

A continuous section of type B-vent may only be used to pass through the roof or outside of the building. Vertical venting (Category III) does not allow the use of type B-vent inside of the space.

For common vertical venting of more than two heaters, See *Page 42, Section 8*.


A vent shall not extend less than 2' (0.6m) above the highest point where it passes through a flat roof of a building.

Note: Vertical venting will be classified as a Category III if the length of the horizontal portion of the vent pipe is greater than 75% of the vertical portion of the vent pipe. (Example: If vertical vent section of the vent is 10' (3 m) long, the horizontal section of the vent is greater than 7' 6" (2.3 m) long.)

8.5 Unvented Operation Tube Termination

Turndown type vent terminal with a screen must be installed at the exhaust end of the tube. Vent terminal design shall not incorporate backdraft flap.

FIGURE 28: Tube Termination



8.6 Length Requirements

The maximum vent length allowed is 45' (13.7 m).
The maximum outside air supply duct length allowed is 45' (13.7 m).

The total vent length, plus outside air duct length, plus any extensions to minimum heat exchanger lengths, cannot exceed 65' (19.8 m).

Vent length should be limited to less than 20' (6 m). If using vent lengths greater than 20' (6 m), condensation will form in the vent pipe. Insulation and additional sealing measures (high temperature silicone at all seams) are required. Optional heat exchanger beyond minimum lengths is considered as vent length for length determination.

Subtract 15' (4.6 m) of maximum allowed vent or duct length per vent elbow if more than two are used.

8.7 Vent Material Recommendations

Vent recommendations:

1. Porcelain coated tubing 4" (10 cm) O.D. (P/N 9141030D)
2. Heat treated aluminized tubing 4" (10 cm) O.D. (P/N 91409408)
- Heat treated aluminized tubing 6" (15 cm) O.D. (P/N E0009105)

3. Single wall pipe (Type-C) that is corrosion resistant galvanized steel - minimum 26 ga. (Supplied by others)


4. Double wall vent (Type-B). Used ONLY as a continuous section passing through the outside wall, roof or outside of the building.

NOTE: 4" (10 cm) O.D. Porcelain coated tubing (P/N 9141030D), 4" (10 cm) O.D. Heat treated aluminized tubing (P/N 91409408), and 6" (15 cm) O.D. Heat treated aluminized tubing (P/N E0009105) are equivalent to single wall flue pipe.

8.8 Horizontal Venting (Category III) 4" (10 cm) Pipe

Note: A continuous section of type B-vent may only be used to pass through the outside wall or outside of the building. Horizontal venting (Category III) does not allow the use of type B-vent inside of the space.

SIDE VIEW




Description	Part Number
Vent Terminal (Comb. Wall)	90502100
Vent Terminal	02537801-XX

Vertical Venting (Category III) 4" (10 cm) Pipe

Note: A continuous section of type B-vent may only be used to pass through the roof or outside of the building. Vertical venting (Category III) does not allow the use of type B-vent inside of the space.

SIDE VIEW




Description	Part Number
Vent Cap 4" (10 cm)	90502300

NOTE:

It is required that all vent pipes and connectors be fastened together with sheet metal screws and sealed with high temperature silicone sealant approved for at least 550 °F (288 °C) (supplied by others). The installer must perform a leak test on the complete venting system. A solution of soap and water should be used to test the venting system.

8.9 Common Side Wall Horizontal Venting (Category III)

Note: A continuous section of type B-vent may only be used to pass through the outside wall or outside of the building. Horizontal venting (Category III) does not allow the use of type B-vent inside of the space.



Requirements:

- Maximum of two heaters can be commonly vented through a side wall.
- Heaters must be of the same BTU output.
- Heaters must be controlled by a common thermostat.

NOTE:


It is required that all vent pipes and connectors be fastened together with sheet metal screws and sealed with high temperature silicone sealant approved for at least 550 °F (288 °C) (supplied by others).

The installer must perform a leak test on the complete venting system. A solution of soap and water should be used to test the venting system.


8.10 Common Vertical Venting (Category III)

Note: A continuous section of type B-vent may only be used to pass through the roof or outside of the building. Vertical venting (Category III) does not allow the use of type B-vent inside of the space.

SIDE VIEW



TOP VIEW



Requirements:

- Maximum of four heaters can be commonly vented through the roof.
- Heaters must be of the same BTU output.
- Heaters must be controlled by a common thermostat.
- Connections to a common stack must be positioned to avoid direct opposition between streams of combustion gases.

NOTE:

It is required that all vent pipes and connectors be fastened together with sheet metal screws and sealed with high temperature silicone sealant approved for at least 550 °F (288 °C) (supplied by others). The installer must perform a leak test on the complete venting system. A solution of soap and water should be used to test the venting system.

8.11 Outside Combustion Air Supply

IMPORTANT: If the building has a slight negative pressure or corrosive contaminants, such as halogenated hydrocarbons, are present in the air, an outside combustion air supply to the heater is required. Seal all combustion air pipe joints.


Use of optional outside combustion air is not recommended with unvented heaters.

The air supply duct may have to be insulated to prevent condensation on the outer surface. The outside air terminal must not be more than 1' (31 cm) above the vent termination while maintaining a minimum distance of 3' (93 cm) for both vertical and horizontal venting.

8.11.1 Length Requirements


Follow the constraints listed on *Page 44, Section 8.6*.

8.11.2 Vertical Outside Air Supply for Single Heater Installation




Description	Part Number
Vent Cap 4" (10 cm)	90502300

8.11.3 Horizontal Outside Air Supply for Single Heater Installation



Description	Part Number
Vent Cap 4" (10 cm)	90502300

8.11.4 Vertical Outside Air Supply for Double Heater Installation




Description	Part Number
Vent Cap 6" (15 cm)	90502302

Requirements:

- Heaters must be controlled by a common thermostat.

8.11.5 Horizontal Outside Air Supply for Double Heater Installation



Description	Part Number
Vent Cap 6" (15 cm)	90502302

- Requirements:
- Heaters must be controlled by a common thermostat.

SECTION 9: GAS PIPING

! WARNING**Fire Hazard**

Tighten gas hose fittings to connect gas supply according to Figure 23.

Gas hose can crack when twisted.

Gas hose moves during normal operation.

Use only 36" (91 cm) long connector of 1/2" or 3/4" nominal ID.

Connector supplied with heater for U.S. models (not with Canadian models).

Failure to follow these instructions can result in death, injury or property damage.

! WARNING**Explosion Hazard**

Leak test all components of gas piping before operation.

Gas can leak if piping is not installed properly.

Do not high pressure test gas piping with heater connected.

Failure to follow these instructions can result in death, injury or property damage.

Install the gas hose as shown on *Page 52, Figure 29*. The gas hose accommodates expansion of the heating system and allows for easy installation and service of the burner. Before connecting the burners to the supply system, verify that all high pressure testing of the gas piping has been completed. There is an expansion of the tube with each firing cycle; this will cause the burner to move with respect to the gas hose. This can cause a gas leak resulting in an unsafe condition if the gas connection is not made strictly in accordance with *Figure 29 on Page 52*.

Meter and service must be large enough to handle all the burners being installed plus any other connected load. The gas hose which feeds the system must be large enough to supply the required gas with a maximum pressure drop of 1/2" w.c. When gas piping is not included in the layout drawing, the local gas supplier will usually help in planning the gas piping.


Gas lines must meet applicable codes:

United States: The Flexible Stainless Steel Gas Hose (US models) supplied with the heater is certified per the Standard for Connectors for Gas Appliances, ANSI Z21.24/CSA 6.10 - latest revision.

Canada: The Rubber Type 1 Gas Hose (Canadian models) optional with the heater is certified as being in compliance with the Standard for Elastomeric Composite Hose and Hose Couplings for Conducting Propane and Natural Gas, CAN/CGA 8.1 - Latest revision.

- **Check the pipe and tubing ends for leaks before placing heating equipment into service. When checking for gas leaks, use a soap and water solution; never use an open flame.**

FIGURE 29: Gas Connection with Flexible Gas Hose



SECTION 10: WIRING


⚠ DANGER**Electrical Shock Hazard****Disconnect electric before service.****Heater must be properly earthed.****Failure to follow these instructions can result in death or electrical shock.**

Note # 6: The DF-Series heater is a dual firing heating unit and must be connected to a low voltage, two-stage thermostat for correct operation. A thermostat connector is provided on the exterior of the burner box. A separate external connection is also provided to energize a two-state low voltage thermostat for convenience. See Section 10.1 for wiring a two-stage thermostat to the burner box. For wiring a single two-stage thermostat to multiple burners, see *Page 54, Section 10.2*.

Heaters must be grounded in accordance with applicable codes: United States: Refer to National Electric Code® NFPA 70- latest revision; Canada: Refer to Canadian Electrical Code CSA C22.1 Part 1 - Latest revision.


If any of the original internal wiring must be replaced, it must be replaced with wiring materials have a temperature rating of at least 221°F (105°C) and 600 volts.

10.1 Dual Stage Low Voltage Thermostat Wiring




Description	Part Number
Dual Stage Low Voltage Thermostat	90425412

POWER SUPPLY
120VAC 60 Hz



NOTE: Two 4PDT relays required for
3 OR 4 burners and one thermostat.

POWER SUPPLY
120VAC 60 Hz




NOTE: Two DPDT relays required for two burners and one thermostat.

NOTE: 1 4PDT relay required for 2 burners and 1 thermostat. 2 4PDT relays required for 3 or 4 burners and 1 thermostat. Maximum of 4 burners per thermostat. 4PDT relay provided by others.





Description	Part Number
Dual Stage Low Voltage Thermostat	90425412

10.3 Internal Wiring





SECTION 11: OPERATION AND MAINTENANCE

⚠ DANGER		⚠ WARNING	
			
Electrical Shock Hazard Disconnect electric before service. Heater must be connected to a properly grounded electrical source.	Explosion Hazard Turn off gas supply to heater before service.	Burn Hazard Allow heater to cool before service. Tubing may still be hot after operation.	Cut/Pinch Hazard Wear protective gear during installation, operation and service. Edges are sharp.
Failure to follow these instructions can result in death, electric shock, injury or property damage.			

This heater is equipped with a direct spark ignition system.

11.1 Sequence of Operation

The DF-Series heater is a dual firing heating unit that must be connected to a two-stage thermostat (P/N - 90425412) for correct operation. The ROBERTS GORDON® two-stage thermostat uses an algorithm that controls whether the heater operates on high or low fire. The algorithm output will vary based on load conditions. For example, if the thermostat does not sense a heat rise during a heat cycle within a certain time, it may prompt the DF-Series heater to operate in high fire. The temperature and timing within the algorithm that causes the DF-series burner to fire in high or low fire varies each heat cycle. The thermostat automatically adjusts the DF-Series output during each cycle to improve operation efficiency.

11.2 High/Low Firing Operation

When the thermostat is turned up, the burner will ignite on low fire. The low fire condition is indicated by the low fire indicator light on the burner box that illuminates when the gas valve opens. The high fire condition is indicated by the high fire indicator light that will illuminate when the gas valve switches to high fire.

11.3 Sequence of Operation

1. Turn the thermostat up. When the two-stage thermostat calls for heat, the ignition module will energize the blower motor.
2. When the motor approaches nominal running RPM, the pressure switch closes and activates the ignition module.
3. The ignition module then opens the two-stage gas valve for low fire operation and energizes the spark igniter.
4. When the flame is established, the sparking sequence ceases. The burner is either operating at high fire or low fire depending on the load conditions sensed by the thermostat. If the burner is on high fire, the high fire indicator light will illuminate immediately. The low fire indicator light will illuminate upon ignition and stay energized while the burner is operation, regardless of the firing rate. If the burner is on low fire, only the low fire indicator light will be illuminated.
5. If the flame is not established during the ignition sequence, the ignition module closes the gas valve and purge begins. Module will try 2 additional times for ignition (with purge in between). If ignition is not established, the module will lock out.
6. If the flame extinguishes during operation, the ignition module will provide multiple trial sequence described in step 5. If ignition is not re-established, the module will lock out.
7. After lockout, control must be reset by turning down thermostat for five seconds, and then raising it again to desired temperature, or by disconnecting power and then reconnecting.
8. When the thermostat is satisfied, all power to the unit is shut off.

11.4 To Shut Off Heater

- Set thermostat to lowest setting.
- Turn OFF electric power to heater.
- Turn OFF manual gas valve in the heater supply line.

11.5 To Start Heater

- Turn gas valve and electric power OFF and wait five minutes for unburned gases to vent from heater.
- Turn ON main gas valve.
- Turn ON electric power.
- Set thermostat to desired temperature.
- Burner should light automatically.

11.6 Pre-Season Maintenance and Annual Inspection

- To ensure your safety and years of trouble-free operation of the heating system, service and annual inspections must be done by a contractor qualified in the installation and service of gas-fired heating equipment.
- Turn off gas and electric supplies before performing service or maintenance. Allow heater to cool before servicing.
- Before every heating season, a contractor qualified in the installation and service of gas-fired heating equipment must perform a thorough safety inspection of the heater.

For best performance, the gas, electrical, thermostat connections, tubing, venting, suspensions and overall heater condition should be thoroughly inspected.

NOTE: Gas flow and burner ignition are among the first things that should be thoroughly inspected. Please see *Page 58, Section 11.7* for suggested items to inspect.

11.7 Maintenance Checklist

Installation Code and Annual Inspections:
All installation and service of ROBERTS GORDON® equipment must be performed by a contractor qualified in the installation and service of equipment sold and supplied by Roberts-Gordon LLC and conform to all requirements set forth in the ROBERTS GORDON® manuals and all applicable governmental authorities pertaining to the installation, service, operation and labeling of the equipment.


To help facilitate optimum performance and safety, Roberts-Gordon LLC recommends that a qualified contractor conduct, at a minimum, annual inspections of your ROBERTS GORDON® equipment and perform service where necessary, using only replacement parts sold and supplied by Roberts-Gordon LLC.

The Vicinity of the Heater	<p>Do not store or use flammable objects, liquids or vapors near the heater. Immediately remove these items if they are present.</p> <p><i>See Page 5, Section 3.</i></p>
Vehicles and Other Objects	<p>Maintain the clearances to combustibles.</p> <p>Do not hang anything from, or place anything on, the heater.</p> <p>Make sure nothing is lodged underneath the reflector, in between the tubes or in the decorative or protective grilles (included with select models).</p> <p>Immediately remove objects in violation of the clearances to combustibles.</p> <p><i>See Page 5, Section 3.</i></p>
Reflector	<p>Support reflector with reflector hanger and support strap.</p> <p>Reflector must not touch tube.</p> <p>Make sure there is no dirt, sagging, cracking or distortion.</p> <p>Do not operate if there is sagging, cracking or distortion.</p> <p>Make sure reflectors are correctly overlapped. <i>See Page 30, Section 6.6.1.</i></p> <p>Clean outside surface with a damp cloth.</p>
Vent Pipe	<p>Venting must be intact. Using a flashlight, look for obstructions, cracks on the pipe, gaps in the sealed areas or corrosion.</p> <p>The area must be free of dirt and dust.</p> <p>Remove any carbon deposits or scale using a wire brush.</p> <p><i>See Page 42, Section 8.</i></p>

Outside Air Inlet	<p>Inlet must be intact. Look for obstructions, cracks on the pipe, gaps in the sealed areas or corrosion.</p> <p>The area must be free of dirt and dust. Clean and reinstall as required.</p>
Tubes	<p>Make sure there are no cracks.</p> <p>Make sure tubes are connected and suspended securely.</p> <p>See Page 16, Section 6.</p> <p>Make sure there is no sagging, bending or distortion.</p> <p>Clean or replace as required.</p>
Gas Line	Check for gas leaks. See Page 51, Section 9.
Burner Observation Window	<p>Make sure it is clean and free of cracks or holes.</p> <p>Clean and replace as required.</p>
Blower Scroll, Wheel and Motor	Compressed air or a vacuum cleaner may be used to clean dust and dirt.
Burner Cup and Orifice	<p>Clear of obstructions (even spider webs will cause problems).</p> <p>Carefully remove any dust and debris from the burner.</p>
Electrode	<p>Replace if there are cracked ceramics, excessive carbon residue, or erosion of the electrode.</p> <p>The electrode gap should be 1/8" (3.2 mm).</p>
Thermostat	<p>There should be no exposed wire or damage to the thermostat.</p> <p>See Page 53, Section 10.</p>
Suspension Points	<p>Make sure the heater is hanging securely. Look for signs of wear on the chain or ceiling.</p> <p>See Page 17, Figure 15.</p>
Decorative and Protective Grille (optional)	<p>The grille must be securely attached.</p> <p>Check that the side reflector extensions are installed correctly and secured in place if necessary. (Decorative grille only.)</p> <p>See Page 39, Section 7.5 and Page 41, Section 7.6</p> <p>Make sure shield is installed correctly and secured in place if necessary. (Decorative grille only.) See Page 40, Section 7.5.2.</p>
Lower Clearance Shield (optional)	<p>The lower shield must be securely attached. Inspect shield support straps and lower clearance shield anchor points.</p> <p>See Page 39, Section 7.4.</p> <p>Make sure shield is installed correctly and secured in place if necessary.</p> <p>See Page 39, Section 7.4.</p>
Wall Tag	If wall tag is present, make sure it is legible and accurate. Please contact Roberts-Gordon LLC or your ROBERTS GORDON® independent distributor, if you need a wall tag. See Page 4, Section 2.1
Safety Labels	Product safety signs or labels should be replaced by the product user when they are no longer legible. Please contact Roberts-Gordon LLC or your ROBERTS GORDON® independent distributor to obtain replacement signs or labels. See Page 2, Figure 1 through Page 3, Figure 2.

SECTION 12: TROUBLESHOOTING

⚠ **DANGER**







Electrical Shock Hazard


Disconnect electric before service.

Heater must be properly earthed.


Failure to follow these instructions can result in death or electrical shock.

⚠ WARNING			
			
<p>Fire Hazard</p> <p>Keep all flammable objects, liquids and vapors the minimum required clearances to combustibles away from heater.</p> <p>Some objects will catch fire or explode when placed close to heater.</p>	<p>Explosion Hazard</p> <p>Turn off gas supply to heater before service.</p>	<p>Burn Hazard</p> <p>Allow heater to cool before service.</p> <p>Tubing may still be hot after operation.</p>	<p>Cut/Pinch Hazard</p> <p>Wear protective gear during installation, operation and service.</p> <p>Edges are sharp.</p>
<p>Failure to follow these instructions can result in death, injury or property damage.</p>			


12.1 Troubleshooting Flow Chart









Module Diagnostic Codes:	
LED	Problem
4 second steady flash at start of cycle	Normal
Steady on	Microprocessor failure within module
Three flashes	Ignition lockout Lockout of module after 3 tries
	Wait for valve to open
	Replace module
	Recycle unit: check for spark and valve opening and replace:if none, replace module




12.2 Manifold Gas Pressure Setting




SECTION 13: REPLACEMENT PARTS

 DANGER		 WARNING	
			
Electrical Shock Hazard	Explosion Hazard	Fire Hazard	Carbon Monoxide Hazard
<p>Use only genuine ROBERTS GORDON® replacement parts per this installation, operation and service manual.</p> <p>Failure to follow these instructions can result in death, electric shock, injury or property damage.</p>			

See warnings and important information before removing or replacing parts. After any maintenance or repair work, always test fire the heater in accordance with the start-up instructions *on Page 57, Section 11* to help ensure all safety systems are in working order before leaving the heater to operate. Minor faults may be traced by using the troubleshooting charts *on Page 60, Section 12 through Page 63, Figure 12.2*.



REAR VIEW
TOP VIEW



Description	Part Number
Mica Window Assembly	02553203
Electrode Gasket	02558501
Tube Gasket	02568200
Burner Cup Assembly	03020100
Gas Valve (Natural)	90034900
Electrode	90427400
DSI Ignition Module	90439500K
Transformer	90436900K
Pressure Switch	
(200)	90439801K
(175)	90439802K
(125, 150)	90439803K
(80, 100)	90439805K
Motor/Blower Assembly	90709700-P
Blower Outlet Gasket	90709801
Burner Status Light	91316103
Relay, SPDT	90447140

SECTION 14: GENERAL SPECIFICATIONS**14.1 Material Specifications****14.1.1 Reflectors**

.024 Aluminum (Standard or High Efficiency Reflectors)
(Optional .024 Stainless Steel Type 304 (Standard Reflectors Only))

14.2 Heater Specifications**14.2.1 Ignition**

Fully automatic, three-try, direct spark, electronic ignition control, 100% safety shut-off.


14.3 Suspension Specifications

Hang heater with materials with a minimum working load of 75 lbs (33 kg). See *Page 17, Figure 15*.

14.4 Controls Specifications

Time switches, thermostats, etc. can be wired into the electrical supply. External controls supplied as an optional extra.

General Specifications for DF-Series heaters are as follows:



*See *Page 5, Section 3* for clearances to combustibles.

GAS PRESSURE AT MANIFOLD:

Natural Gas: 3.5" wc
LP Gas: 10.5" wc

PIPE CONNECTION:

1/2" NPT

DIMENSIONS:

Vent Connection Size: 4" (10 cm)

Outside Air Connection Size: 4" (10 cm)

Refer to figure above for dimensional information.

ELECTRICAL RATING (ALL MODELS):

120 V - 60 Hz, 1 A (run)

GAS INLET PRESSURE:**Natural Gas:**

for BH-40, 60, 80, 100,
115, 125, 140, 150
for BH-175, 200

4.6" wc Minimum

5.0" wc Minimum

14.0" wc Maximum

LP Gas:

11.0" wc Minimum

14.0" wc Maximum

**PRODUCT "TYPE" ACCORDING TO ASHRAE HANDBOOK-
HVAC SYSTEMS AND EQUIPMENT (LATEST EDITION)**

Type: "C" - Indirect Tube-Type Heater (Forced Draft)

SECTION 15: THE ROBERTS GORDON® GORDONRAY® DF WARRANTY

ROBERTS-GORDON LLC WILL PAY FOR:

Within 36 months from date of purchase by buyer or 42 months from date of shipment by Roberts-Gordon LLC (whichever occurs first), replacement parts will be provided free of charge for any part of the product which fails due to a manufacturing or material defect.

Roberts-Gordon LLC will require the part in question to be returned to the factory. Roberts-Gordon LLC will, at its sole discretion, repair or replace after determining the nature of the defect and disposition of part in question.

ROBERTS GORDON® Replacement Parts are warranted for a period of 12 months from date of shipment from Roberts-Gordon LLC or the remaining ROBERTS GORDON® GORDONRAY® DF warranty.

ROBERTS-GORDON LLC WILL NOT PAY FOR:

Service trips, service calls and labor charges.

Shipment of replacement parts.

Claims where the total price of the goods have not been paid.

Damage due to:

- Improper installation, operation or maintenance.
- Misuse, abuse, neglect, or modification of the ROBERTS GORDON® GORDONRAY® DF in any way.
- Use of the ROBERTS GORDON® GORDONRAY® DF for other than its intended purpose.
- Incorrect gas or electrical supply, accident, fire, floods, acts of God, war, terrorism, or other casualty.
- Improper service, use of replacement parts or accessories not specified by Roberts-Gordon LLC.
- Failure to install or maintain the ROBERTS GORDON® GORDONRAY® DF as directed in the Installation, Operation and Service Manual.
- Relocation of the ROBERTS GORDON® GORDONRAY® DF after initial installation
- Use of the ROBERTS GORDON® GORDONRAY® DF in a corrosive atmosphere containing contaminants.
- Use of the ROBERTS GORDON® GORDONRAY® DF in the vicinity of a combustible or explosive material.
- Any defect in the ROBERTS GORDON® GORDONRAY® DF arising from a drawing, design, or specification supplied by or on behalf of the consumer.
- Damage incurred during shipment. Claim must be filed with carrier.

WARRANTY IS VOID IF:

The ROBERTS GORDON® GORDONRAY® DF is not installed by an contractor qualified in the installation and service of gas fired heating equipment.

You cannot prove original purchase date and required annual maintenance history.

The data plate and/or serial number are removed, defaced, modified or altered in any way.

The ownership of the ROBERTS GORDON® GORDONRAY® DF is moved or transferred. This warranty is non-transferable.

Roberts-Gordon LLC is not permitted to inspect the damaged equipment and/or component parts.

READ YOUR INSTALLATION, OPERATION AND SERVICE MANUAL.

If you have questions about your equipment, contact your installing professional. Should you need Replacement Parts or have additional questions, call or write:

Roberts-Gordon LLC

1250 William Street

P.O. Box 44

Buffalo, New York 14240-0044

Telephone: +1.716.852.4400

Fax: +1.716.852.0854

Toll Free: 800.828.7450

www.robertsgordon.com

Roberts-Gordon LLC's liability, and your exclusive remedy, under this warranty or any implied warranty (including the implied warranties of merchantability and fitness for a particular purpose) is limited to providing replacement parts during the term of this warranty. Some jurisdictions do not allow limitations on how long an implied warranty lasts, so this limitation may not apply to you. There are no rights, warranties or conditions, expressed or implied, statutory or otherwise, other than those contained in this warranty.

Roberts-Gordon LLC shall in no event be responsible for incidental or consequential damages or incur liability for damages in excess of the amount paid by you for the ROBERTS GORDON® GORDONRAY® DF.

Some jurisdictions do not allow the exclusion or limitation of incidental or consequential damages, so this limitation or exclusion may not apply to you. This warranty gives you specific legal rights, and you may also have other rights which vary from jurisdiction to jurisdiction.

Roberts-Gordon LLC shall not be responsible for failure to perform under the terms of this warranty if caused by circumstances out of its control, including but not limited to war, fire, flood, strike, government or court orders, acts of God, terrorism, unavailability of supplies, parts or power. No person is authorized to assume for Roberts-Gordon LLC any other warranty, obligation or liability.

LIMITATIONS ON AUTHORITY OF REPRESENTATIVES:

No representative of Roberts-Gordon LLC, other than an Executive Officer, has authority to change or extend these provisions. Changes or extensions shall be binding only if confirmed in writing by Roberts-Gordon LLC's duly authorized Executive Officer.

ROBERTS GORDON®
 INFRARED HEATING

OWNER WARRANTY REGISTRATION CARD

Mail or Fax to:

 Roberts Gordon LLC • 1250 William Street, P.O. Box 44 • Buffalo, NY 14240-0044 • Phone: 716-852-4400 • Fax: 716-852-0854
www.robertsgordon.com
About the Owner:

 Name: _____
 Address: _____ City: _____ State: _____ Zip Code: _____
 Phone: _____ Fax: _____ E-mail: _____

About the Installer:

 Name: _____
 Address: _____ City: _____ State: _____ Zip Code: _____
 Phone: _____ Fax: _____ E-mail: _____

Purchased From (if different than installer):

 Name: _____
 Address: _____ City: _____ State: _____ Zip Code: _____
 Phone: _____ Fax: _____ E-mail: _____

About your Heater:

Model #: _____ Serial #: _____ Fuel: _____ Installation Date: _____

Type of Installation (check one):

<input type="checkbox"/> Automotive	<input type="checkbox"/> Manufacturing	<input type="checkbox"/> Warehouse	<input type="checkbox"/> Recreational	<input type="checkbox"/> Aircraft
<input type="checkbox"/> Public Building	<input type="checkbox"/> Office	<input type="checkbox"/> Retail	<input type="checkbox"/> Agricultural	<input type="checkbox"/> Other _____

Installation Code and Annual Inspections: All installation and service of ROBERTS GORDON® equipment must be performed by a contractor qualified in the installation and service of equipment sold and supplied by Roberts-Gordon LLC and conform to all requirements set forth in the ROBERTS GORDON® manuals and all applicable governmental authorities pertaining to the installation, service, operation and labeling of the equipment.

To help facilitate optimum performance and safety, Roberts-Gordon LLC recommends that a qualified contractor conduct, at a minimum, annual inspections of your ROBERTS GORDON® equipment and perform service where necessary, using only replacement parts sold and supplied by Roberts-Gordon LLC.

These products are not for residential use.

This product is intended to assist licensed professionals in the exercise of their professional judgment.

©2020 Roberts-Gordon LLC - All rights reserved. No part of this work covered by the copyrights herein may be reproduced or copied in any form or by any means – graphic, electronic, or mechanical, including photocopying, recording, taping, or information storage and retrieval systems – without written permission of Roberts Gordon LLC.
 Printed in the U.S.A.

Attach this information to a wall near the ROBERTS GORDON® heater.

ROBERTS GORDON®


Infrared Heating

Read the Installation, Operation, and Service Manual thoroughly before installation, operation, or service.

Know your model number and installed configuration.

Model number and installed configuration are found on the burner and in the Installation, Operation and Service Manual.

Write the largest clearance dimensions with permanent ink according to your model number and configuration in the open spaces below.

OPERATING INSTRUCTIONS	⚠ WARNING
<ol style="list-style-type: none"> 1. STOP! Read all safety instructions on this information sheet. 2. Open the manual gas valve in the heater supply line. 3. Turn on electric power to the heater. 4. Set the thermostat to desired setting. 	 <p>Fire Hazard</p> <p>Keep all flammable objects, liquids and vapors the minimum required clearances to combustibles away from heater.</p> <p>Some objects will catch fire or explode when placed close to heater.</p> <p>Failure to follow these instructions can result in death, injury or property damage.</p>
TO TURN OFF THE HEATER	
<ol style="list-style-type: none"> 1. Set the thermostat to off or the lowest setting. 	
IF THE HEATER WILL NOT OPERATE, TO ENSURE YOUR SAFETY, FOLLOW THESE INSTRUCTIONS TO SHUT DOWN YOUR HEATER	
<ol style="list-style-type: none"> 1. Set the thermostat to off or the lowest setting. 2. Turn off electric power to the heater. 3. Turn off the manual gas valve in the heater supply line. 4. Call your registered installer/contractor qualified in the installation and service of gas-fired heating equipment. 	

**Maintain _____ clearance
to the side and
_____ clearance below
the heater from vehicles
and combustible materials.**

Roberts-Gordon LLC
1250 William Street
P.O. Box 44
Buffalo, NY 14240-0044 USA
Telephone: +1.716.852.4400
Fax: +1.716.852.0854

Installation Code and Annual Inspections:

All installation and service of ROBERTS GORDON® equipment must be performed by a contractor qualified in the installation and service of equipment sold and supplied by Roberts-Gordon and conform to all requirements set forth in the ROBERTS GORDON® manuals and all applicable governmental authorities pertaining to the installation, service, operation and labeling of the equipment. To help facilitate optimum performance and safety, Roberts-Gordon recommends that a qualified contractor conduct, at a minimum, annual inspections of your ROBERTS GORDON® equipment and perform service where necessary, using only replacement parts sold and supplied by Roberts-Gordon.

Further Information: Applications, engineering and detailed guidance on systems design, installation and equipment performance is available through ROBERTS GORDON® representatives. Please contact us for any further information you may require, including the Installation, Operation and Service Manual.

This product is not for residential use.

© 2017 Roberts-Gordon LLC

All rights reserved. No part of this work covered by the copyrights herein may be reproduced or copied in any form or by any means – graphic, electronic, or mechanical, including photocopying, recording, taping, or information storage and retrieval systems – without written permission of Roberts-Gordon LLC.

www.robertsgordon.com

P/N 91037912 Rev. K